



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA192947

Certificate Holder: Pink River Pty Ltd
675 Macarthur Ave Central
Pinkenba QLD 4008
Australia

Class Description: Non-Prescribed
Product Description: Surge Protection Device
Trade Name: OBO BETTERMANN
Model No.: V50-3+NPE+FS-280
Markings: Uc (50/60Hz) L-N: 280Vac; Iimp L-N 12.5kA;
In: L-N: 30kA; Up L-N: ≤1.3kV;
Uc (50/60Hz) N-PE: 255Vac; Iimp N-PE: 50kA;
In: N-PE: 50kA; Up N-PE: ≤1.5kV;
T1 T2
Standard: IEC 61643-11 Ed. 1.0
Conditions: Nil

Certification Mark: RCM and SAA192947

Date First Registered: 11 December 2019

Date of Expiry: 11 December 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 11-12-19 192947/1

www.jas-anz.org/register